



NOTES:

1. TOP OF BLOCKING TO BE 2 INCHES FROM HYDRANT WEEP HOLES.
2. IF HYDRANT IS LOCATED ON A DEPARTMENT OF TRANSPORTATION ROADWAY USE D.O.T. STANDARDS FOR LOCATION OF HYDRANT.
3. HYDRANT SHALL BE LOCATED FROM 2 TO 15 FEET FROM BACK OF CURB.
4. HYDRANT MAY BE LOCATED (AT LEAST 1 FOOT) BEHIND SIDEWALK WHEN IT CANNOT BE LOCATED INSIDE THE UTILITY STRIP.
5. HYDRANT SHALL BE INSTALLED AT LEAST 2 FEET BEYOND TOP SLOPE OF ANY DRAINAGE DITCHES. HYDRANT INSTALLATION WITHIN THE DITCH LINE OR SLOPE SHALL BE PROHIBITED.
6. STANDARD WEDGE ACTION RETAINER GLANDS MAY BE SUBSTITUTED WITH 3/4 INCH STAINLESS STEEL RODDING IN ORDER TO ACHIEVE CONTINUOUS RESTRAINT BETWEEN THE HYDRANT AND THE MAIN.
7. HYDRANT EXTENSIONS ARE PROHIBITED.
8. WITHIN THE TOWN OF MORRISVILLE ONLY, HYDRANTS NEAR FDC'S SHALL BE PROVIDED WITH A STORZ CONNECTION.



STANDARD HYDRANT INSTALLATION FOR ROADS WITH CURB & GUTTER

DETAIL No.

6000.07

EFFECTIVE: 07/01/21