



NOTES:

1. VALVE OPERATOR EXTENSION SHALL BE INSTALLED IN ALL CASES WHERE THE VALVE OPERATOR IS GREATER THAN 6-FT DEPTH FROM THE SURFACE.
2. HORIZONTAL GATE VALVES SHALL ONLY BE INSTALLED WHERE VERTICAL ALIGNMENT IS NOT POSSIBLE DUE TO DEPTH, MINIMUM CLEARANCE, OR OTHER CONFLICTS.



**RESILIENT WEDGE GATE VALVE ASSEMBLY FOR RECLAIMED WATER
(HORIZONTAL INSTALLATIONS)**

DETAIL No.

6500.15

EFFECTIVE: 07/01/21