



CROSS SECTION

NOTES:

1. MINIMUM PUBLIC UTILITY SEPARATION DISTANCES ARE MEASURED FROM THE EDGE OF PIPE.
2. THERE SHALL BE AN 18 INCH VERTICAL SEPARATION BETWEEN WATER AND SEWER LINES WHEN DIRECTLY OVERHEAD.
3. DEPENDING ON PUBLIC UTILITY ALIGNMENT, ADDITIONAL EASEMENT MAY BE REQUIRED OUTSIDE OF THE RIGHT-OF-WAY. SEE STANDARD SPECIFICATION 7010.A.1.d FOR EASEMENT WIDTH REQUIREMENTS.
4. ENCROACHMENT ONTO TOWN MAINTAINED RIGHT-OF-WAY SHALL FOLLOW CONDITIONS OF THE APPLICABLE ENCROACHMENT AGREEMENT OR FRANCHISE AGREEMENT.
5. FOR FIRE HYDRANT LOCATION SEE STD. DETAIL 6000.07 AND 6000.10.
6. MINOR SPACING ADJUSTMENTS MAY BE NECESSARY ON SMALLER STREET CROSS-SECTIONS.



EFFECTIVE: 07/01/22

STANDARD UTILITY LOCATIONS IN STREET CROSS SECTION

DETAIL No.

3000.26