



- NOTES:**
1. VALVE OPERATOR EXTENSION SHALL BE INSTALLED IN ALL CASES WHERE THE VALVE OPERATOR IS GREATER THAN 6 FOOT DEPTH FROM THE SURFACE.
  2. ADDITIONAL JOINT RESTRAINT REQUIRED IN EACH DIRECTION (NOT SHOWN) FOR INLINE VALVE TO OPERATE AS A DEAD END.

RESILIENT WEDGE GATE VALVE ASSEMBLY  
FOR VERTICAL INSTALLATIONS

DETAIL No.

6000.16

