


MINIMUM CONCRETE BLOCKING (C.Y.) *					
NOMINAL PIPE DIAMETER INCHES	TEES & DEAD ENDS	90° BEND	45° BEND	22½° BEND	11¼° BEND
4	⅓	⅓	⅓	⅓	⅓
6	⅓	⅓	⅓	⅓	⅓
8	⅓	½	⅓	⅓	⅓
10	⅔	¾	½	⅓	⅓
12	¾	1.0	⅔	⅓	⅓

NOTES:

1. FITTING SHALL BE WRAPPED WITH A MINIMUM 4 MIL PLASTIC.
2. NO CONCRETE SHALL COVER BOLTS OR GLANDS.
3. PIPE DIAMETERS BEYOND 12 INCHES SHALL UTILIZE A PROFESSIONAL ENGINEER'S SEALED DESIGN CONSISTING OF RESTRAINED JOINT PIPE OR BLOCKING.

* CONCRETE SHALL BE 3,000 P.S.I. MIX.



EFFECTIVE: 07/01/22

STANDARD REACTION BLOCKING

DETAIL No.

6000.21