


NOTES:

1. THIS DETAIL SHALL APPLY ONLY TO TEMPORARY CAPPING. PERMANENT DEAD END LINES TO BE IN ACCORDANCE WITH STANDARD DETAIL 6000.18.
2. REQUIRED RESTRAINT AWAY FROM THE DEAD END MAY BE MJ PIPE WITH WEDGE ACTION RESTRAINTS FOR PIPE < 12 INCH DIAMETER.
3. 3/4" ALL-THREADED, STAINLESS STEEL RODS (CUT TO LENGTH). FASTENERS SHALL ALSO BE STAINLESS STEEL. RODDING SHALL NOT EXCEED 10 FEET IN LENGTH.
4. USE ONE THREADED ROD PER 2 INCHES OF PIPE DIAMETER, e.g., 8" PIPE REQUIRES 4 RODS.




**TYPICAL
EYE BOLT**

TEMPORARY AC PIPE TO DIP CAP

DETAIL No.

6000.37



EFFECTIVE: 07/01/22