

- 3. STORMWATER CATCH BASINS SHALL BE PROVIDED AS ILLUSTRATED ON DETAIL 3100.02.
- 4. EITHER A NORMAL CROWN OF 0.02' PER FOOT OR A CONTINUOUS SUPERELEVATION OF 0.02 PER FOOT IS ALLOWED.
- 5. PAVEMENT DESIGN SHALL BE REQUIRED AND APPROVED BY **NCDOT** (FOR NCDOT ROADS) AND/OR CARY PRIOR TO PLACEMENT OF ANY BASE MATERIAL.
- 6. PAVEMENT DESIGN SHALL BE AS SHOWN OR AS DESIGNED BY GEOTECHNICAL ENGINEER, WHICHEVER IS GREATER.
- 7. DEPENDING ON PUBLIC UTILITY ALIGNMENT, ADDITIONAL EASEMENT MAY BE REQUIRED OUTSIDE OF THE RIGHT-OF-WAY. SEE STANDARD SPECIFICATION 7010.A.1.d FOR EASEMENT WIDTH REQUIREMENTS.



STANDARD TWO-WAY RESIDENTIAL ALLEY

DETAIL No.

3000.24