

ACTUAL PIPE SIZE SHALL  
BE SHOWN ON ALL PLANS  
& DESIGNED BY A FIRE  
PROTECTION ENGINEER OR  
SPRINKLER SYSTEM  
DESIGNER

TO SPRINKLER RISER  
(SEE DETAIL 6000.27 FOR CONNECTION)

WALL PLATE  
(TYPICAL)

SCH. 40 STEEL

WALL

FIRE DEPARTMENT CONNECTION

PIPE TAP FOR BALL  
DRIP VALVE

HORIZONTAL MOUNTED  
BALL DRIP VALVE


30" TO 42"

PIPE TO OUTSIDE

FLOOR

EXISTING GRADE

WALL MOUNTED FIRE DEPARTMENT CONNECTION



EFFECTIVE: 07/01/23

DETAIL No.

6000.29