



SECTION VIEW

NOTES:  
 1. PIPING SHALL BE 2-INCH COPPER OR SCHEDULE 40 PVC.  
 2. ENTIRE ASSEMBLY SHALL BE LOCATED IN A DEDICATED CARY EASEMENT OR AS DIRECTED.



EFFECTIVE: 07/01/23

STANDARD AUTOMATIC FLUSHING DEVICE

DETAIL No.  
6000.33