


NOTES:

1. ON STATE ROADS, THE FIRE HYDRANT SHALL BE LOCATED BEHIND THE DITCH.
2. WITHIN THE TOWN OF MORRISVILLE ONLY, HYDRANTS NEAR FDC'S SHALL BE PROVIDED WITH A STORZ CONNECTION.
3. REFER TO DETAIL 6000.07 FOR LOCATION OF HYDRANT GATE VALVE.



EFFECTIVE: 07/01/24

STANDARD HYDRANT INSTALLATION FOR ROADS WITHOUT CURB & GUTTER

DETAIL No.
6000.08