



- NOTES:**
1. VALVE OPERATOR EXTENSION SHALL BE INSTALLED IN ALL CASES WHERE THE VALVE OPERATOR IS GREATER THAN 6 FOOT DEPTH FROM THE SURFACE.
 2. ADDITIONAL JOINT RESTRAINT REQUIRED IN EACH DIRECTION (NOT SHOWN) FOR ALL VALVES TO OPERATE AS A DEAD END.



EFFECTIVE: 07/01/24

RESILIENT WEDGE GATE VALVE ASSEMBLY
FOR VERTICAL INSTALLATIONS

| |
|------------|
| DETAIL No. |
| 6000.16 |