



SECTION A-A

TOP VIEW

SECTION B-B

- NOTES:
1. ALL MANHOLE CONNECTIONS SHALL BE PREFABRICATED OR CORED WITH A CONCRETE CORING MACHINE.
 2. ALL MANHOLES SHALL BE VACUUM TESTED.
 3. EXTENDED BASE REQUIRED FOR ALL MANHOLES WITH MORE THAN 12-FT DEPTH OF BURY.
 4. PROVIDE A MINIMUM 0.1 FOOT IN-OUT DROP FOR STRAIGHT RUNS AND 0.2 FOOT IN-OUT DROP FOR ANGLE RUNS.
 5. PROVIDE ONLY FIRST AND LAST STEP IN MANHOLE.

STANDARD PRECAST CONCRETE MANHOLE
6-FT DIAMETER OR LARGER FOR NON-PAVED AREAS

DETAIL No.

7000.02



EFFECTIVE: 07/01/24