



- NOTES:
1. ACCESS HATCH AND METER VAULT SHALL BE RATED FOR H-20 LOADING.
 2. FOR PLUG VALVES LARGER THAN 6 INCHES, MINIMUM CLEARANCE SHALL BE INCREASED TO 12 INCHES AND CONTRACTOR SHALL VERIFY ADEQUATE CLEARANCE FOR WHEEL OPERATOR.

PLAN VIEW
(SEE SHEET 1 OF 2 FOR SECTION VIEW)

STANDARD MAG METER INSTALLATION



EFFECTIVE: 07/01/24

DETAIL No.
7200.05
SHEET 2 OF 2