



**NOTES:**

1. SLIDE GATE SHALL HAVE A STRONG LOCK MECHANISM, DROP ROD, AND TRUSS ROD.
2. ALL FENCE COMPONENT MATERIALS SHALL BE EITHER HOT DIPPED GALVANIZED STEEL OR IRON. FENCE FABRIC SHALL BE ALUMINUM COATED WITH BLACK UV RESISTANT VINYL.
3. ALL FENCING SHALL BE PROVIDED WITH A BLACK VINYL COATED POLYESTER PRIVACY SCREEN ACROSS THE ENTIRE SURFACE AREA OF THE FENCE INCLUDING GATES.
4. POSTS SHALL ALSO BE VINYL COATED WITH BLACK UV RESISTANT VINYL.
5. USE MINIMUM 9 GAUGE GALVANIZED 'EASY TWIST' FENCE TIES FOR BINDING FENCE AND PRIVACY SCREEN, PER 2 FEET SPAN VERTICALLY, ON EACH 2", 3" OR 4" POST. PLASTIC "ZIP TIES" ARE NOT ALLOWED.
6. AN AUTOMATED SLIDE GATE AND CONTROLS ARE REQUIRED FOR PUMP STATIONS WITH CAPACITY OF 0.75 MGD OR GREATER.



EFFECTIVE: 07/01/24

**CHAIN LINK FENCE & GATE**

DETAIL No.

7500.07