



- NOTES:**
1. THE HYDRAULIC JUMP SAMPLE VAULT TO BE USED WHERE SEWER ELEVATION PERMITS.
  2. IF SITE CONDITIONS DO NOT ALLOW FOR INSTALLATION OF SAMPLE VAULT, OUTLET TEE ASSEMBLY SHALL BE 6" DIAMETER.
  3. 3'X3'X3' SAMPLE VAULT SHALL BE CONNECTED ON THE EFFLUENT DISCHARGE PIPE OF A CARY APPROVED GREASE INTERCEPTOR.