

Town of Cary Pump Station Inspection Sheet



Facility Name: Thomas Brooks P.S.

Inspection Date:

ID Number: 029

Pump

Type: Submersible

Discharge Diameter: 8"

Control: VFD

Motor Horsepower: 20

Manufacturer: Fairbanks Morse

Model: DJ5433MV

913-371-5000

Wetwell: 6' Diameter

Condition: Fair

Pump One: 159 gpm

Pump Two: 160 gpm

Firm Capacity 159 gpm

Rep:

828-324-9' HD Supply

Comments:

-removed from service

Town of Cary Pump Station Inspection Sheet



Thomas Brooks PS Pump Curves:

